











| Building Energy Performance | | Scotland |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------|
| Energy Performance Certificate | Calculated asset rating using iSBEM v3.5.b [SBEM] | Building type Restaurant/public house |
| | Current rating | |
| | Excellent | |
| |  | Carbon Neutral |
| |  | A (0 to 15) |
| |  | B (16 to 30) |
| |  | C (31 to 45) |
|  | D (46 to 60) | |
|  | E (61 to 80) | |
|  | F (81 to 100) | |
|  | G (100+) | |
| Very Poor | | |
| Carbon Dioxide Emissions | | |
| The number refers to the calculated carbon dioxide emissions in terms of kg per m ² of floor area per year | | 92 |
| Approximate current energy use per m ² of floor area: | | 403 kWh/m² |
| Main heating fuel: Natural Gas | | Building Services: Heating with Nat. Vent. |
| Renewable energy source: | | Electricity: Grid supplied |
| Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment. | | |
| Benchmarks | | |
| A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating: | | 72  E |
| Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating: | | 88  F+ |
| Recommendations for the cost-effective improvement (lower cost measures) of the energy performance | | |
| 1. Improve insulation on HWS storage. | 4. The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements. | |
| 2. Consider replacing T8 lamps with retrofit T5 conversion kit. | 5. Some windows have high U-values - consider installing secondary glazing. | |
| 3. Some spaces have a significant risk of overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows. | 6. Add weather compensation controls to heating system. | |

Address: Mains Of Scotstown AB22 8WT, 1 Jesmond Square, ABERDEEN, AB22 8WT
Conditioned area (m²): 620
Name of protocol organisation: Stroma Accreditation Ltd, [00000034555]
Date of issue of certificate: 02 Mar 2011 (Valid for a period not exceeding 10 years)
 This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.
NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE