

Energy performance certificate (EPC)

Queens Arms
Great North Road
Barnet
EN5 1AB

Energy rating

C

Valid until:

16 November 2035

Certificate number:

1935-9711-6672-7711-8003

Property type

Restaurants and Cafes/Drinking
Establishments/Takeaways

Total floor area


684 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

29 B

If typical of the existing stock

116 E

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	61.98
Primary energy use (kWh/m ² per year)	399

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/4758-7869-6328-1729-2813\)](/energy-certificate/4758-7869-6328-1729-2813).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mr Terry Tsakistras, DipNDEA, DipNDEA(Scotland), DipDEC, DipGDNDA, BOHS P402.
Telephone	0780 8292 535
Email	info@tagepc.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/028269
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Trinity Alexander Group info@tagepc.co.uk
Employer address	15 Whitehall, Westminster, London SW1A 2DD
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	12 November 2025
Date of certificate	17 November 2025

Energy performance certificate (EPC) recommendation report

Queens Arms
Great North Road
Barnet
EN5 1AB

Report number
4758-7869-6328-1729-2813

Valid until
16 November 2035

Energy rating and EPC

This property's energy rating is C.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
Improve insulation on HWS storage.	Low
In some spaces, the solar gain limit defined in the NCM is exceeded, which might cause overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	Medium

Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Some windows have high U-values - consider installing secondary glazing.	Medium
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	Medium
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	Medium

Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	Medium
Roof is poorly insulated. Install or improve insulation of roof.	Medium
Consider installing solar water heating.	Low
Consider installing PV.	Low

Additional recommendations

Recommendation	Potential impact on carbon emissions
Consider replacing T8 lamps with new LED luminaires with new controls	Medium

Property and report details

Report issued on	17 November 2025
Total useful floor area	684 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	G-ISBEM Ltd, G-ISBEM, v25.3, SBEM, v6.1.e.0

Assessor's details

Assessor's name	Mr Terry Tsakistras, DipNDEA, DipNDEA(Scotland), DipDEC, DipGDNDA, BOHS P402.
Telephone	0780 8292 535
Email	info@tagepc.co.uk
Employer's name	Trinity Alexander Group info@tagepc.co.uk
Employer's address	15 Whitehall, Westminster, London SW1A 2DD
Assessor ID	EES/028269
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Elmhurst Energy Systems Ltd
